
From: Planning.APWest [REDACTED]
Sent: 23 March 2023 09:26
To: planningservices
Subject: stw ref P-230301-39436 / 23/0106 THE ALLENS CENTRE, HILTON ROAD,
WILLENHALL, WV12 5XB

CAUTION: STOP and THINK - This email originated from outside of the council. If it looks suspicious it probably is and you should NEVER enter your council username and password into an external link or open attachments.

ST Classification: UNMARKED

Good Day,

Thank you for the opportunity to comment on this planning application. Please find our response noted below:

With Reference to the above planning application the company's observations regarding sewerage are as follows.

I can confirm that we have no objections to the proposals subject to the inclusion of the following condition:

- The development hereby permitted should not commence until drainage plans for the disposal of foul and surface water flows have been submitted to and approved by the Local Planning Authority, and
- The scheme shall be implemented in accordance with the approved details before the development is first brought into use. This is to ensure that the development is provided with a satisfactory means of drainage as well as to prevent or to avoid exacerbating any flooding issues and to minimise the risk of pollution.

Severn Trent Water advise that there is a public 150mm foul sewer, a public 225mm foul sewer, a public 375mm surface water sewer and a public 525mm surface water sewer located within this site. Public sewers have statutory protection and may not be built close to, directly over or be diverted without consent. You are advised to contact Severn Trent Water to discuss the proposals. Severn Trent will seek to assist in obtaining a solution which protects both the public sewer and the building. Please note, when submitting a Building Regulations application, the building control officer is required to check the sewer maps supplied by Severn Trent and advise them of any proposals located over or within 3 meters of a public sewer. Under the provisions of Building Regulations 2000 Part H4, Severn Trent can direct the building control officer to refuse building regulations approval.

Please note that there is no guarantee that you will be able to build over or close to any Severn Trent sewers, and where diversion is required there is no guarantee that you will be able to undertake those works on a self-lay basis. Every approach to build near to or divert our assets has to be assessed on its own merit and the decision of what is or isn't permissible is taken based on the risk to the asset and the wider catchment it serves. It is **vital** therefore that you contact us at the earliest opportunity to discuss the implications of our assets crossing your site. Failure to do so could significantly affect the costs and timescales of your project if it transpires diversionary works need to be carried out by Severn Trent.

· 100mm to 299mm diameter - 3m either side of the pipe, measured from the centreline of the sewer.
· 300mm to 999mm diameter - 5m either side of the pipe, measured from the centreline of the sewer.

Site specific comments: having viewed the submitted "Flood Risk Assessment and Surface Water Drainage Assessment" (ref: 680535-R1(02)-FRA) and Development Enquiry (SAP Ref 1069598) we would request the above drainage condition is applied, with particular attention to the public sewers crossing the site. The proposed layout within the report appears to show the proposed dwellings to be situated over the public sewers which cross the site; I have checked the Development Enquiry and can see the applicant was made aware of these sewers, but I have been unable to locate any further mention of them in communications via the Development Enquiry and have been

unable to locate a S185 sewer diversion application. Can the applicant please confirm the proposals in relation to these assets.

IMPORTANT NOTE: This response only relates to the public waste water network and does not include representation from other areas of Severn Trent Water, such as the provision of water supply or the protection of drinking water quality.

Please note if you wish to respond to this email please send it to [REDACTED] where we will look to respond within 10 working days.

If your query is regarding drainage proposals, please email to the aforementioned email address and mark for the attention of Planning Liaison Technician.

Kind regards,

Asset Protection Team
Severn Trent

Asset Protection (West)
Severn Trent Water - Waste Water Services
[REDACTED]